



Potable Water Risk Analysis Summary for the period 2017-02-01 to 2017-02-28 according to SANS 241 - 2015

As on 3 April 2017

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	375	369	98.40	Good
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	96	96	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	968	968	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 517	1 492	98.35	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	536	536	100.00	Excellent

