



Potable Water Risk Analysis Summary for the period 2016-09-01 to 2016-09-30 according to SANS 241 - 2015

As on 4 November 2016

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	386	383	99.22	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	88	88	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 017	1 017	100.00	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 547	1 532	99.03	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	532	530	99.62	Excellent

