



Potable Water Risk Analysis Summary for the period 2019-01-01 to 2019-01-31 according to SANS 241 - 2015

As on 4 March 2019

	NAME	DESCRIPTION	No.ANALYSIS	No.Compliant Analysis	% COMPLIANCE	EXPLANATION
1.	Drinking Water Quality Compliance	Acute Health Microbiological Compliance (AHMC)	392	390	99.49	Excellent
2.	Drinking Water Quality Compliance	Acute Health Chemical Compliance (AHCC)	92	92	100.00	Excellent
3.	Drinking Water Quality Compliance	Chronic Health Chemical Compliance (CHCC)	1 071	1 070	99.91	Excellent
4.	Drinking Water Quality Compliance	Operational Compliance (ORC)	1 579	1 568	99.30	Excellent
5.	Drinking Water Quality Compliance	Aesthetic Compliance (AC)	580	579	99.83	Excellent

